

ASSESSING UTILITY SCALE ENERGY STORAGE ECONOMICS CONSIDERING GENERATION ADEQUACY SERVICES

Prof. Anderson Rodrigo de Queiroz

Raleigh, 02/20/23




Overview

Introduction

- Modeling Approach & Assumptions
- Results North Carolina Case
- Impacts of Storage in Dispatch Costs -Brazil
- Final Comments

Introduction

Energy Storage Options for North Carolina




to NC consumers

incentive for energy storage

Peak Capacity Deferral


- It refers to the practice of delaying the construction or installation of new generation capacity until it is necessary to meet peak electricity
- How storage can contribute to postpone investments in generation



Hourly steps ordered by descending demand magnitude

Bulk Energy Time Shifting

Practice of shifting the delivery of large amounts of energy from one period to another. Take advantage of differences in demand & prices



Modeling Approach & Assumptions

Optimization Model Overview

Energy system optimization model (Temoa) used for two purposes:



The TEMOA Project

https://github.com/TemoaProject

Capacity expansion planning (CEP) <u>ttp://temoaproject.org</u>

for the area in analysis under different scenario configuration





Patankar, N., Eshraghi, H., de Queiroz, A. R., & DeCarolis, J. F. (2022). Using robust optimization to inform US deep decarbonization planning. Energy Strategy Reviews, 42, 100892

 Operational dispatch considering system configurations from CEP and different deployment of storage technologies




de Queiroz, A. R., Mulcahy, D., Sankarasubramanian, A., Deane, J. P., Mahinthakumar, G., Lu, N., & DeCarolis, J. F. (2019) Repurposing an energy system optimization model for seasonal power generation planning. Energy, 181, 1321-1330






Approach, Data and Assumptions



Data & Assumptions



- Existing power generators represented as individual power plants
- Future generators grouped by their respective generation class



EIA Annual Electric Generator data, form <u>EIA-860</u> EIA electric utility data survey, form <u>EIA-923</u> <u>EIA's U.S. Electric System Operating Data Tool</u> NREL Annual Technology Baseline - <u>ATB</u> NREL Solar and Wind Energy Resource Assessment - <u>SWERA</u>


Analysis Scenarios

- 1. Base case
- 2. Duke IRP
- 3. Expanded RP

- 2017 Carolinas Power generation system
- HB589 solar PV deployments (5.9 GW by 2022)
- Fixed representation of the exchanges
- Scenario matches the build-outs proposed by Duke's 2 IRP
 - RPS expanded to 2030 with a target of 40% for renewables (solar, wind, biomass, small hydro)
- Clean Energy Standard
- 60% target of clean energy sources by 2030
- 5. Carbon Cap Duke's 2017 Climate Report to Shareholders: 40% reduction in 2005 CO₂ emissions levels
- 6. Natural Gas Price High Projection from EIA AEO 2018
- 7. Deployment of Plug-in Electric Vehicles

Results – North Carolina Case


Base Case – Installed Capacity



Charging/Discharging Profile - Ll-1GW/4GWh

DICCULADCING

Example of a charging profile for a LI-1GW/4GWh during the course of 8760 hours in the operational model run



KEY	DISCHARGING														HAK									
	-0										-0	0	0	0	0									0


CUADCING



LI-1GW/1GWh LI-1GW/2GWh LI-1GW/4GWh



50




Operational Model Runs

LI-5GW/5GWh LI-5GW/15GWh LI-5GW/20GWh

No Storage

50



Cost-Benefits Assessment

□ Energy Saving S→ Operational dispatch costs with storage $ES_i^k = TC_{NS} - TC_i \quad \forall i \in I_k, \forall k \in K$ Operational dispatch costs without □ Capacity Value storage Cost of new entry Gas CT (\$/kW-year) $CV_i^k = (ECP_i \times P_i)CONE \forall i \in I_k, \forall k \in K$ Capacity (kW) → Capacity credit Total Benefits (%) $SB_i^k = ES_i^k + CV_i^k \quad \forall i \in I_k, \forall k \in K$ Finding the best storage configuration $\operatorname{argmax}\{SB_i^k - (P_i \times RR_i^k)\}$ Storage revenue requirement (\$/kW-*CONE for a Gas CT estimated at 113 (\$/kW-year)

Total Benefits vs Revenue Requirements

Total net benefits (\$/kWyr) of lithium-ion batteries and pumped hydro for **shifting energy** over time and **deferring new investments** in

Generation Juration LI (2019) LI (2030)									
	(h)	0.3GW	•		5GW	0.3GW	``		5GW
	1	-100	-101	-102	-100	-13	-14	-15	-13
Base Case	2	-80	-81	-84	-86	12	11	8	6
	4	-117	-119	-125	-131	5	3	-4	-10
	1	-87	-97	-101	-101	0	-10	-14	-14
Duke IRP	2	-67	-78	-83	-86	25	14	9	6
	4	-105	-117	-126	-133	17	5	-4	-11
Ermandad	1	-77	-90	-95	-96	10	-3	-8	-9
Expanded REPS	2	-52	-65	-72	-75	41	27	20	17
	4	-80	-95	-105	-111	42	27	17	11
Clean	1	-99	-99	-101	-101	-12	-12	-14	-14
Energy	2	-66	-79	-82	-83	26	13	11	9
Standard	4	-100	-115	-120	-125	21	7	2	-3
Carbon	1	-97	-98	-100	-100	-10	-11	-13	-13
Сапоон Сар	2	-75	-77	-80	-82	17	15	12	11
-	4	-109	-111	-117	-122	13	10	5	0
High	1	-95	-87	-95	-97	-8	0	-8	-10
Natural	2	-42	-64	-73	-76	50	28	19	16
Gas Price	4	-70	-94	-107	-116	52	28	14	6
Electric	1	-111	-106	-105	-105	-24	-19	-18	-18
Vehicles	2	-93	-88	-89	-91	-1	4	4	1
	4	-134	-131	-136	-143	-12	-9	-14	-21

	duration	PSH					
	(h)	0.3GW	1GW	3GW	5GW		
Base Case	8	53	47	30	14		
Duke IRP	8	64	48	29	12		
Expanded REPS	8	110	94	75	61		
Clean Energy Standard	8	67	60	45	30		
Carbon Cap	8	73	67	52	38		
High Natural Gas Price	8	111	83	56	34		
Electric Vehicles	8	26	27	12	-1		


We can observe that several configurations of Li-Ion and PSH would provide positive benefits to the NC system projected to 2030



Impacts of Storage in Dispatch Costs - Brazil


Modeling Framework – Brazilian System

- Hydro-dominant Power System (~70% of production of 65GWavg)
- Individual Hydro and Thermal Plants Representation
- Interconnection between Regions
- De-rating factor, efficiency, capacity factor, and transmission losses




PORTAL SINTEGRE <

Results – 1GW/4h Deployed in the Northeast



Results – 2GW/8h Deployed in the Southeast



Impacts in Total Operational Dispatch Costs

		Operational Costs	Yearly ≠	% ≠
-	Caso Base	R\$ 3,095,735,478.81	-	-
2021	0.5GW/4h NE	R\$ 3,027,438,253.09	R\$ 68,297,225.72	2.21%
Z	1GW/4h NE	R\$ 2,968,356,135.78	R\$ 127,379,343.03	4.11%
10	2GW/4h NE	R\$ 2,873,845,056.25	R\$ 221,890,422.56	7.17%
PMO JAN	4GW/24h NE	R\$ 2,802,850,998.80	R\$ 292,884,480.01	9.46%
4	2GW/8h SE	R\$ 2,721,487,681.82	R\$ 374,247,796.99	12.09%
	Caso Base	R\$ 12,062,398,526.10	-	I
õ	0.5GW/4h NE	R\$ 11,986,997,334.80	R\$ 75,401,191.30	0.63%
2030	1GW/4h NE	R\$ 11,921,727,024.20	R\$ 140,671,501.90	1.17%
PDE	2GW/4h NE	R\$ 11,812,433,223.20	R\$ 249,965,302.90	2.07%
ē.	4GW/24h NE	R\$ 11,821,421,457.50	R\$ 240,977,068.60	2.00%
	2GW/8h SE	R\$ 11,754,140,482.30	R\$ 308,258,043.80	2.56%

Significant reductions in terms of total operational dispatch costs, reaching 12% in a case with 2GW/8h of pumped hydro storage placed in the Southeast region of the country

Final Comments

- This is the first comprehensive open-source modeling effort to develop projections for the Carolinas power system
- It can be used to assess economic, technical, and policy futures and provide valuable insights to decision makers
- Model and analyze other scenarios, e.g.:
 - Bidirectional capabilities for EVs
 - 100% of clean energy
 - Wider range of future fuel prices and policies
- Framework adapted to investigate energy storage in Brazil
- Collaboration with Polytechnic de Torino to look at Italy and European cases



Thank You !

adequeiroz@nccu.edu ardequei@ncsu.edu https://ardequeiroz@github.io







Raleigh, February 2023